



OFFICIAL LISTING

NSF International Certifies that the products appearing on this Listing conform to the requirements of NSF/ANSI Standard 61 - Drinking Water System Components - Health Effects

This is the Official Listing recorded on May 12, 2017.

Enecon Corporation
6 Platinum Court
Medford, NY 11763
800-436-3266
516-349-0022



Facility: Medford, NY

Protective (Barrier) Materials

Trade Designation	Water Contact Size Restriction	Water Contact Temp	Water Contact Material
Coatings - Fittings CHEMCLAD SC [1] [2]	>= 6"	CLD 23	EPOXY
Coatings - Pipe CHEMCLAD SC [1] [2]	>= 12"	CLD 23	EPOXY
Coatings - Pump CHEMCLAD SC [1] [2]	>= 4"	CLD 23	EPOXY
Coatings - Tank CHEMCLAD SC [1] [2]	>= 1 gal.	CLD 23	EPOXY
Coatings - Valve CHEMCLAD SC [1] [2]	>= 6"	CLD 23	EPOXY

[1] Colors: Gray, haze gray, white
 Number of Coats: 2 - 4
 Maximum Field Use Dry Film Thickness (in mils): 28 (7 mils per coat)
 Recoat Cure Time and Temperature: 24 hours at 77°F
 Final Cure Time and Temperature: 4 days at 77°F
 Special Comments: Mix ratio of Base:Activator is 3.29:1 by weight.

[2] Certification does not include Chemclad P4C.